



भारतीय रिज़र्व बैंक Reserve Bank of India
संपदा विभाग Estate Department
बेंगलूरु Bengaluru

Pre-Bid Meeting Minutes: Design, Supply, Installation, Testing, and Commissioning of 2 x120 kVA and 2 x 100 kVA Uninterrupted Power Supply Systems in N+1 Parallel Redundant Mode (Including the Battery Banks) at Main Office Building, Reserve Bank of India, Bengaluru

E-Tender ID: [2026 RBI 292285 1](#)

The 'Pre-Bid Meeting' for the captioned work was conducted as per schedule at 11.00 AM, on September 29, 2026 at Meeting Room, 2nd Floor, Estate Department, Reserve Bank of India, Bengaluru. The following staff members of RBI and representatives of the prospective bidders were present during the pre-bid meeting:

Sl. No.	Name and designation of the RBI officials
1.	Shri Vyom Gupta, DGM (Estate)
2.	Shri Suresh Kumar K, AM (Tech - Ele)
3.	Smt. Deepika Purohit, AM (Estate)
4.	Shri Chandrakanta B, AM (Estate)
5.	Shri. Prajwal Kabburkar, JE(Ele)

Sl. No.	Name of the prospective bidders	Name of the representative
1.	M/s Riello Power India Pvt. Ltd.	Shri G. Prakash
2.	M/s Delta Electronics India Pvt. Ltd.	Shri Karibasajjaiah. H. H
3.	M/s Power One Micro Systems Pvt. Ltd.	Shri S. Venkatesh
4.	M/s Accutech	Shri Mahantes

The following queries / issues were raised / discussed during the pre-bid meeting. The clarifications given by the Bank with respect to each of these queries / issues are as follows:

Sl. No.	Query / Proposal/ Existing condition	Bank's response / revised condition
1	All vendor representatives from the prospective bidders unanimously recommended	The vendors have been formally advised to submit their requests for an extension of the bid submission deadline in writing,

	extending the deadline for bid submission to ensure adequate time for comprehensive proposal preparation.	providing clear justification, for consideration by the Bank.
2	What type of cables shall be used for the Input and Output Power Supply Arrangement?	The Bank's Engineer has clarified that the prospective bidders shall comply with the technical specifications outlined in Clause 4.0 of Section VI of the tender document.
3	What is the prescribed make and model of the UPS to be supplied, including any specific technical specifications or certifications required?	The Bank's Engineer has clarified that the UPS to be supplied shall fully comply with the technical specifications outlined in Clause 6.0 of Section VI of the tender document and also shall comply with the eligibility criteria outlined in the tender document.
4	What is the periodicity of the All-Inclusive Maintenance Contract (CAMC)?	The Bank's Engineer has clarified that the periodicity of the CAMC shall mandatorily comply with the specifications outlined in Clause 21.0 of Section VI of the tender document.

The vendors present were then taken for a tour of the site for better understanding of the scope of work.

Note: Above amendments / clarifications are issued for information to all intending bidders. Minutes of the pre-bid meeting shall form part of tender. All other parts of the tender document continue to remain unaltered. Submission of tenders shall be construed to be in conformity to the bid document and amendments/clarifications.

**Regional Director
Reserve Bank of India
Bengaluru**